

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 13/05/2026

It is certified that an inspection team headed by

SHASHI KUMAR (C.S.I.) (Name of Officers with designation)

from NAGAR NIGAM SRINAGAR PHED

inspected the DEVBHUMI PUBLIC SCHOOL, NAKOT SRINAGAR GARHWAL

(Name & Address of the school) on (date of inspection) and on the basis

of Water Test Report (Attached) bearing no.....

dated..... of (PHED Lab)


certified that the

..... (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 31/03/2027

thirty one March
Twenty Seven
Two


To DEVBHUMI PUBLIC SCHOOL
NAKOT SRINAGAR GARHWAL
(Name & Address of the Institution)

Signature with Seal: 
Name : SHASHI KUMAR (गढ़वाल)
Designation : C.S.I.
Name & Address of the Office / Department :

NAGAR NIGAM SRINAGAR


मुख्य स्वास्थ्य निरीक्षक,
नगर निगम
श्रीनगर (गढ़वाल)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Principal
Devbhumi Public School
Nakot, Srinagar Garhwal (U.K.)


Chairman
Devbhumi Public School
Nakot, Srinagar-Garhwal (U.K.)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Agency Mohalla Near Pump House,
Srinagar Garhwal

Ph (O): 01346-252995, E-mail: uj.s.eepauri@gmail.com



TC-12709

Name and Address of Organization/Customer	Dev Bhoomi Public School, Nakot, Srinagar Garhwal.		
Test Report ID	268/UJS/DLWQTMLS/2024-25	Reporting Date	25/01/2025
URL No.		Sample Location	Dev Bhoomi Public School, Nakot, Srinagar Garhwal.
Product Description	Drinking Water	Sample Collected by	Umed Singh Bhandari
Reference Sample Identification:	DLWQTML/UJS/DB-01		
Date of start of Analysis:	24/01/2025		
Date of End of Analysis:	25/01/2025		
Date and Time of Sample Received:	24/01/2025, 12.10pm		

TEST REPORT


SN	Parameters	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source	Test Method
1.	Colour, Hazen, Max	1.0	5	15	IS 3025 (Part- 4)
2.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-05)
3.	pH at 25 ^o C	8.28	6.5 to 8.5	No Relaxation	IS 3025 (Part-11)
4.	Turbidity, NTU, Max	Less than 0.50	1	5	IS 3025 (Part-10)
5.	Total Dissolved Solids (TDS) at 180 ^o C, mg/L, Max	356.0	500	2000	IS 3025 (Part-16)
6.	Chloride, mg/L, Max	25.5	250	1000	IS 3025 (Part-32)
7.	Total Hardness (as CaCO ₃), mg/L, Max	164.0	200	600	IS 3025 (Part -21)
8.	Calcium (as Ca), mg/L, Max	47.2	75	200	IS 3025 (Part-40)
9.	Magnesium (as Mg), mg/L, Max	11.18	30	100	APHA 24rd Ed.-3500-Mg Method B (By Calculation)
10.	Total Alkalinity (as CaCO ₃), mg/L, Max	170.0	200	600	IS 3025 (Part 23)


Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer


**** End of Report****

Checked By


Principal
Devbhumi Public School
Nakot, Srinagar Garhwal (U.K.)


Chairman
Devbhumi Public School
Nakot
Srinagar Garhwal

Review and Authorized By


(Er. Pooja Dhanai)
Authorized Signatory, Lab
Authorized Signatory
District Level Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan, Srinagar



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Agency Mohalla Near Pump House,
Srinagar Garhwal

Ph (O): 01346-252995, E-mail: uj.s.eepauri@gmail.com



TC-12709

Name and Address of Organization/Customer	Dev Bhoomi Public School, Nakot, Srinagar Garhwal.		
Test Report ID	268/UJS/DLWQTMLS/2024-25	Reporting Date	25/01/2025
URL No.		Sample Location	Dev Bhoomi Public School, Nakot, Srinagar Garhwal.
Product Description	Drinking Water	Sample Collected by	Umed Singh Bhandari
Reference Sample Identification:	DLWQTML/UJS/DB-01		
Date of start of Analysis:	24/01/2025		
Date of End of Analysis:	25/01/2025		
Date and Time of Sample Received:	24/01/2025, 12.10pm		

TEST REPORT


SN	Parameters	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source	Test Method
1.	Colour, Hazen, Max	1.0	5	15	IS 3025 (Part- 4)
2.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-05)
3.	pH at 25 ^o C	8.28	6.5 to 8.5	No Relaxation	IS 3025 (Part-11)
4.	Turbidity, NTU, Max	Less than 0.50	1	5	IS 3025 (Part-10)
5.	Total Dissolved Solids (TDS) at 180 ^o C, mg/L, Max	356.0	500	2000	IS 3025 (Part-16)
6.	Chloride, mg/L, Max	25.5	250	1000	IS 3025 (Part-32)
7.	Total Hardness (as CaCO ₃), mg/L, Max	164.0	200	600	IS 3025 (Part -21)
8.	Calcium (as Ca), mg/L, Max	47.2	75	200	IS 3025 (Part-40)
9.	Magnesium (as Mg), mg/L, Max	11.18	30	100	APHA 24rd Ed.-3500-Mg Method B (By Calculation)
10.	Total Alkalinity (as CaCO ₃), mg/L, Max	170.0	200	600	IS 3025 (Part 23)


Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer


**** End of Report****

Checked By


Principal
Devbhumi Public School
Nakot, Srinagar Garhwal (U.K.)


Chairman
Devbhumi Public School
Nakot
Srinagar Garhwal

Review and Authorized By


(Er. Pooja Dhanai)
Authorized Signatory, Lab
Authorized Signatory
District Level Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan, Srinagar